



Republic of the Philippines
Province of Albay
CITY OF TABACO

Bids and Awards Committee

SUPPLEMENTAL BID BULLETIN NO. 05-2025

**Supply, Delivery & Installation of Airconditioning Units at
Legislative Building, Karangahan Boulevard, Tabaco City
Contract ID No. 004-01-2025-GOODS-PB, ABC: Php 3,000,000.00
PhilGEPS ITB Ref No. 11666254**

TO ALL CONCERNED:

Please be advised of the following amendments and clarifications to the Bidding Documents for the foregoing project, to wit:


Clause 19.3 Section III-Bid Data Sheet, Section VI-Schedule of Requirements, Section VII-Technical Specifications, and Annex A – Price Schedule

	ISSUES	AMENDMENTS/ CLARIFICATION
<u>Item No.</u>	Description	Description
1	<i>Split Type Aircon 1hp With Installation</i> <u>14 degree</u> Temp setting; <u>J-tech Inverter</u> ; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation; <u>Dimension: 877 x 292 x 222mm</u>	<i>Split Type Aircon 1hp With Installation</i> 16 degree Temp setting; Inverter type ; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.
2	<i>Split Type Aircon 1.5HP With Installation</i> <u>14 degree</u> Temp setting; <u>J-tech Inverter</u> ; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation; <u>Dimension: 877 x 292 x 222mm</u>	<i>Split Type Aircon 1.5HP With Installation</i> 16 degree Temp setting; Inverter type ; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.
3	<i>Split Type Aircon 2.0HP With Installation</i> <u>14 degree</u> Temp setting; <u>J-tech Inverter</u> ; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation; <u>Dimension: 877 x 292 x 222mm</u>	<i>Split Type Aircon 2.0HP With Installation</i> 16 degree Temp setting; Inverter type ; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.
4	<i>4HP 3TR Floor Mounted Airconditioner Inverter Including Installation</i> Inverter Technology; Wide Ambient Operation Range; Wide Voltage Range; Universal Match Remote Control; Auto Clean Function; <u>Dimension: 581 x 1870 x 395</u>	<i>4HP 3TR Floor Mounted Airconditioner Inverter Including Installation</i> Inverter Technology; Wide Ambient Operation Range; Wide Voltage Range; Universal Match Remote Control; Auto Clean Function.
5	Installation of Circuit Breaker Protection (NEMA 3R for Outdoor unit), appropriate size of feeder wires shall be provided. Fabrication of brackets and chipping of walls and drainage system	Installation of Circuit Breaker Protection (NEMA 3R for Outdoor unit), appropriate size of feeder wires shall be provided; Fabrication of brackets and chipping of walls and drainage system and restoration works.

This Supplemental Bid Bulletin No. 05-2025 is issued by the procuring entity to clarify, modify or amend items in the Bidding Documents. This shall form an integral part of the Bidding Documents.

For information and guidance of all concerned.

Issued this 27th day of January 2025 at Tabaco City.


ATTY. JOVITO BRON CODERIS, JR.
City Legal Officer / BAC Chairman

Procuring Entity: City Government of Tabaco City
Contract ID No.: 004-01-2025-GOODS-PB
Name of the Project: Supply, Delivery & Installation of Airconditioning Units
Location of the Project: Legislative Building, Karangahan Boulevard, Tabaco City

Schedule of Requirements
(Amended, SBB No. 05-2025)

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

<u>Item No.</u>	<u>Description</u>	<u>QTY</u>	<u>UOM</u>
I.	Supply, Delivery and Installation of the following:		
1	Split Type Aircon 1hp With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.	12	units
2	Split Type Aircon 1.5HP With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.	5	units
3	Split Type Aircon 2.0HP With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.	1	unit
4	4HP 3TR Floor Mounted Airconditioner Inverter Including Installation Inverter Technology; Wide Ambient Operation Range; Wide Voltage Range; Universal Match Remote Control; Auto Clean Function.	4	units
5	Installation of Circuit Breaker Protection (NEMA 3R for Outdoor unit), appropriate size of feeder wires shall be provided; Fabrication of brackets and chipping of walls and drainage system and restoration works.	1	lot
II.	Delivery Period: 30 Calendar Days from Receipt of the Notice to Proceed. Delivery Place: Legislative Building, Karangahan Boulevard, Tabaco City Delivery and Installation Site (see attached ACU Layout Plans)		

I hereby certify to comply and deliver all of the above requirements.

_____ Name of the Company/Bidder	_____ Signature over Printer Name of Authorized Representative	_____ Date
-------------------------------------	--	---------------

Technical Specifications
(Amended, SBB No. 05-2025)

**Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.*

Item	Specification	Statement of Compliance*	Brand of item offered
1	Split Type Aircon 1hp With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.		
2	Split Type Aircon 1.5HP With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.		
3	Split Type Aircon 2.0HP With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.		
4	4HP 3TR Floor Mounted Airconditioner Inverter Including Installation Inverter Technology; Wide Ambient Operation Range; Wide Voltage Range; Universal Match Remote Control; Auto Clean Function.		
5	Installation of Circuit Breaker Protection (NEMA 3R for Outdoor unit), appropriate size of feeder wires shall be provided; Fabrication of brackets and chipping of walls and drainage system and restoration works.		

Name of the Company/Bidder

Signature over Printer Name of
Authorized Representative

Date

Procuring Entity: City Government of Tabaco City
Contract ID No.: 004-01-2025-GOODS-PB
Name of the Project: Supply, Delivery & Installation of Airconditioning Units
Location of the Project: Legislative Building, Karangahan Boulevard, Tabaco City

Price Schedule for Goods Offered from Within the Philippines (Amended, SBB No. 05-2025)

Name of Bidder _____ Project ID No. _____ Page ____ of ____

1	2	3	4	5	6	7	8	9	10
Item	Description	Country of origin	Quantity	Unit price EXW per item	Transportation and all other costs incidental to delivery, per item	Sales and other taxes payable if Contract is awarded, per item	Cost of Incidental Services, if applicable, per item	Total Price, per unit (col 5+6+7+8)	Total Price delivered Final Destination(col 9) x (col 4)
1	Split Type Aircon 1hp With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.		12 units						
2	Split Type Aircon 1.5HP With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.		5 units						
3	Split Type Aircon 2.0HP With Installation 16 degree Temp setting; Inverter type; Operation: 12 hours on/off timer; Eco Mode 0.5 degree Celsius; Coanda Airflow System; Baby sleep mode; Low Voltage Power Operation.		1 unit						
4	4HP 3TR Floor Mounted Airconditioner Inverter Including Installation		4 units						

	Inverter Technology; Wide Ambient Operation Range; Wide Voltage Range; Universal Match Remote Control; Auto Clean Function.								
5	Installation of Circuit Breaker Protection (NEMA 3R for Outdoor unit), appropriate size of feeder wires shall be provided; Fabrication of brackets and chipping of walls and drainage system and restoration works.		1 lot						

Name: _____

Legal Capacity: _____

Signature: _____

Duly authorized to sign the Bid for and behalf of: _____